


NOTES: BELOW GRADE APPLICATION

1. THE TOTAL COMBINED HEIGHT OF SOUND FOOTINGS™ FOOTING FORM MUST NOT EXCEED THIRTEEN FEET (13').
2. SCREW CONSTRUCTION TUBE TO FOOTING FORMS WITH A MINIMUM OF FOUR (4) 3/4" - 1" WOOD SCREWS.
3. SOUND FOOTINGS™ FOOTING FORMS MUST BE PLACED ON UNDISTURBED GROUND OR 4"-6" COMPACTED GRAVEL.
4. CHECK ALIGNMENT OF CONSTRUCTION TUBE BEFORE BACKFILLING.
5. BACKFILL MUST BE PLACED UP TO LIFT 1, APPROXIMATELY 16" OF BACKFILL FROM THE BOTTOM OF THE FOOTING FORM. BACKFILL SHOULD BE CONSOLIDATED WITH A MANUAL PLATE TAMPER OR A 2"x4" ON END. MECHANICAL PLATE COMPACTION EQUIPMENT MAY BE USED TO FACILITATE COMPACTION. DO NOT STRIKE SOUND FOOTINGS™ FOOTING FORM. DO NOT OVER CONSOLIDATE SO AS TO DISTORT THE SHELL OF FOOTING FORM.
6. COMPLETE BACKFILL OF BELOW GRADE PIERS UP TO A MAXIMUM HEIGHT OF FIVE FEET (5'). EACH LIFT SHOULD BE CONSOLIDATED WITH A MANUAL PLATE TAMPER OR A 2"x4" ON END.

UNDISTURBED GROUND OR 4" TO 6" COMPACTED CRUSHED STONE OR GRAVEL



SOUND FOOTINGS™ FOOTING FORM
 BELOW GRADE APPLICATION

SIZE	SF-28	DWG. NO.	SF-105	REV.
SCALE	1" = 1'	DATE	2/27/02	SHEET 5 of 9